

WINTER TEMPERATURE = 10°F. TEMP. RISE = 98°F.
BTUs CALCULATED OFF ACTUAL AIR DENSITY
OUTPUT BTUs AT ALTITUDE OF 0.0 ft. = 544333
INPUT BTUs AT ALTITUDE OF 0.0 ft. = 591666

WINTER TEMPERATURE = 10°F. TEMP. RISE = 98°F.
BTUs CALCULATED OFF ACTUAL AIR DENSITY
OUTPUT BTUs AT ALTITUDE OF 0.0 ft. = 544333
INPUT BTUs AT ALTITUDE OF 0.0 ft. = 591666



Refer to Plumbing Details
Unit Condensate Drain

- 1) 1" diameter PVC Pipe only
- 2) Use only low profile couplings
- 3) Add clean out as shown

FOR QUESTIONS CALL THE
CAPTIVEAIRE
SOUTHERN CALIFORNIA OFFICE
STONE MILL DESIGN CENTER
2915 RED HILL AVE, SUITE C106
COSTA MESA, CA 92626
TEL: 800-967-7701 EMAIL: REG86@CAPTIVEAIRE.COM

[illegible]